



Substitution Request Form

Specified Item: _____

Specification Section: **Masonry Accessories / Sealants**

Proposed Substitution: **UniverSeal US-100 Liquid Tape™**

Performance Characteristics	
Polyether based, moisture curing, elastomeric, vertical seam sealer.	
Skin Over Time	25 min. @ 72°F 40%RH
Set Time(60 mil film)	1 hour @ 72°F 40% RH
VOC's	Very Low - 15.9 grams per liter
Durometer	27 Shore A
Exposure	6 months
Application Temperature	Above 30° F
Solids	100%

Technical data sheet includes product description, specifications, performance and test data adequate for evaluation of the request. If not present, is available at www.yorkmfg.com or 1-800-551-2828

The undersigned certifies that the following paragraphs, unless modified by attachments, are correct:

1. The proposed substitution does not affect dimensions shown on drawings.
2. The proposed substitution will have no adverse effect on the other trades, the construction schedule, or specified warranty requirements.
3. Local support and availability will be available for proposed substitution.
4. Mock-up wall materials available upon request.

The undersigned further states that the function and quality of the proposed product substitution is equivalent or superior to the specified item.

Submitted by: _____

Firm: _____

Address: _____

Phone: _____ Fax: _____

Email: _____

Signature: _____

Corporate Officer: _____

Printed Name: _____

Date: _____

A & E Review
Date: _____ / _____ / _____
Accepted _____
Not Accepted _____
Address: _____
Accepted as noted _____
Remarks: